


Govt.Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya

Sample Collected By :-		NATIONAL HERALD PUBLIC SCHOOL S.S NAGAR, SALEMPUR, Gaya												Sample Received on : 18/03/26					
Sample no	Block Name	Panchayat Name	Village	Wardno	Turb	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphats	Bacteria (+)	Remarks
1	Manpur	Manpur	Salempur	53	0.47	250	162	116	38.48	0.12	45.99	136	0.43	7.39	-	-	5	Absent	
Reporting Date :		23.03.26	Desirable Limit		1.00 NTU	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45	(mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
Limit in absence of alternate source IS: 10500:2012					5.00 NTU	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR		400 (mg/l)	Absent	

*NR-No Relaxation, BDL-Below Detection Limit

जल नमूना का संग्रह दिनांक 18.03.26
S.elisfaकै द्वारा किया गया है ।


Chemist 27.03.26

P.H.Division, Gaya